

Lead in Schools Project

ELC School Drinking Water & Kitchens

with Plumbed in coolers being serviced by **WCS Ltd** Sampling Date of 1 March & 8th March 2017

Site	Contract	Address	Location of cooler (example staff room 1st floor)	Test Result	Pass/Fail	Cooler Serial number
			Sample Number and location of Sample point within School	Limit 10 ugPb/L		
New Dunbar Primary School	8243	Lochend Campus - Kellie Road - Dunbar				8243-001
School already Sampled upon completion 2011		Lochend Campus - Kellie Road - Dunbar	School Already Sampled upon completion in 2011			8243-002
		Lochend Campus - Kellie Road - Dunbar				8243-003
		Lochend Campus - Kellie Road - Dunbar				8243-004
		Lochend Campus - Kellie Road - Dunbar				8243-005
		Lochend Campus - Kellie Road - Dunbar				8243-006
		Lochend Campus - Kellie Road - Dunbar	Staff Room Kitchen Sink Sampled in 2011	< 1	PASS	8243-007
Sample Taken 16/11/2011 result <1Pb/L		Lochend Campus - Kellie Road - Dunbar	Kitchen Cold Water Tap (Food Prep) Sampled in 2011	< 1	PASS	
Musselburgh Community Facility	7758	East Lothian Council - Balcarres Road - Musselburgh				07925
		East Lothian Council - Balcarres Road - Musselburgh				7900
Windygoul Primary School	1151	Brotherstones Way - Tranent - East Lothian	Sample No 17EL39 Outside P1 Water Cooler	< 1 ugPb/L	PASS	4510
		Brotherstones Way - Tranent - East Lothian	Sample No 17EL40 Main Foyer Water Cooler	< 1	PASS	4513
		Brotherstones Way - Tranent - East Lothian	Sample No 17EL41 Cloakroom P2 Water Cooler	< 1	PASS	4515
		Brotherstones Way - Tranent - East Lothian	Sample No 17EL42 Outside P6 Water Cooler	< 1	PASS	4516
		Brotherstones Way - Tranent - East Lothian	Sample No 17EL43 Kitchen Cold Tap	< 1	PASS	7623
		Brotherstones Way - Tranent - East Lothian	Sample No 17EL44 School Kitchen	< 1	PASS	
Wallyford Primary School	1148	39 Salters Road - Wallyford - East Lothian	Sample No 17EL45 Outside Main Office	< 1	PASS	7834
		39 Salters Road - Wallyford - East Lothian	Sample No 17EL46 Left Fountain at GP Room	< 1	PASS	0131
		39 Salters Road - Wallyford - East Lothian	Sample No 17EL47 Right Fountain at GP Room	< 1	PASS	1148
			Sample No 17EL48 Kitchen Food Prep Tap	< 1	PASS	
Sandersons Wynd (Tranent) Primary School	1147	Sandersons Wynd - Tranent - East Lothian				4291
School already sampled upon completion 2011		Sandersons Wynd - Tranent - East Lothian	School already sampled upon completion 2011			4222
		Sandersons Wynd - Tranent - East Lothian				4225

		Sandersons Wynd - Tranent - East Lothian				4230
		Sandersons Wynd - Tranent - East Lothian				4501
		Sandersons Wynd - Tranent - East Lothian				001147
Sample taken 16/11/2011 Result <1Pb/L		Sandersons Wynd - Tranent - East Lothian	School Kitchen Cold Water Tap Sampled in 2011	< 1	PASS	
Prestonpans Nursery School	1140	12 Kirk Street - Prestonpans - East Lothian	Not Sampled as told now part of Infant School			09042
		12 Kirk Street - Prestonpans - East Lothian	Not Sampled as told now part of Infant School			5576
Olivebank Children's Centre	1135	104 Market Street - Musselburgh - East Lothian	Not within FMS			04106006
Kings Meadow Primary School	1124	Neilson Park Road - Haddington - East Lothian	Sample No 17EL115 Staff Room Water Cooler	< 1	PASS	2746
		Neilson Park Road - Haddington - East Lothian	Sample No 17EL116 Kitchen Cold Water food prep Tap	< 1	PASS	
Innerwick Primary School	1123	Kirk Brae - Innerwick - East Lothian	Sample No 17EL117 Water Cooler	< 1	PASS	42707
			Sample No 17EL118 Kitchen Cold Water Tap	< 1	PASS	
Loch Sports Centre	1127	Loch Road - Tranent - East Lothian	Not within FMS			4499
Loch Sports Centre	1127	Loch Road - Tranent - East Lothian	Not within FMS			4502
Loch Sports Centre	1127	Loch Road - Tranent - East Lothian	Not within FMS			0 01023
Site	Contract	Address	Location of cooler (example staff room 1st floor)	Test Result	Pass/Fail	Cooler S/N
			Janitor to record on bottle location within school	Limit 10 ugPb/L		
Gullane Primary School	1117	Muirfield Terrace - Gullane - East Lothian	Sample No 17EL49 Water Fountain Art Area	< 1	PASS	042683
			Sample No 17EL50 Kitchen Cold Water Food Prep	< 1	PASS	
Athelstaneford Primary School	1109	Main Street, Athelstaneford - North Berwick - East Lothian	Sample No 17EL121 Water Cooler Main Entrance	< 1	PASS	042681
			Sample No 17EL122 Dining Hall	< 1	PASS	
Cockenzie Primary School	1112	Osborne Terrace - Port Seton - East Lothian	Sample No 17EL51 Cooler Dining Hall	< 1	PASS	042675
		Osborne Terrace - Port Seton - East Lothian	Sample No 17EL52 Cooler Main Corridor	< 1	PASS	042676
		Osborne Terrace - Port Seton - East Lothian	Sample No 17EL53 Cooler First Floor	< 1	PASS	7794
		Osborne Terrace - Port Seton - East Lothian	Sample No 17EL54 Kitchen Tap Food Prep	< 1	PASS	
Dirleton Primary	1113	Main Street - Dirleton - East Lothian	Sample No 17EL55 Cooler outside boys Toilets	< 1	PASS	042687
		Main Street - Dirleton - East Lothian	Sample No 17EL56 Kitchen Tap Food Prep	< 1	PASS	
Yester Primary School	1152	Walden Terrace - Gifford - East Lothian	Sample No 17EL119 Water Cooler no 2534460	< 1	PASS	YESTER 01
			Sample No 17EL120 Kitchen Tap Food Prep	< 1	PASS	

St Marys Nursery School	1132	Tynebank Road - Haddington - East Lothian	NOT SAMPLED AS PART OF NEW JOINT CAMPUS			
St Martins Primary	1143	160 High Street - Tranent - East Lothian	Sample No 17EL70 Drinking Fountain 1 Room7	< 1	PASS	
St Martins Primary	1143	160 High Street - Tranent - East Lothian	Sample No 17EL57 Drinking Fountain 2 Primary 1	< 1	PASS	052943
		160 High Street - Tranent - East Lothian	Sample No 17EL58 Kitchen Tap cold water food prep	< 1	PASS	052944
Stenton Primary School	1145	Main Street - Stenton - East Lothian	Sample No 17EL123 Water Cooler	< 1	PASS	09017
			Sample No 17EL124 Kitchen Tap	< 1	PASS	
Pencaitland Primary School	1137	The Glebe - Pencaitland - Tranent,	Sample No 17EL125 Upper Area 1	< 1	PASS	2685
		The Glebe - Pencaitland - Tranent,	Sample No 17EL126 Upper Area 2	< 1	PASS	4382
		The Glebe - Pencaitland - Tranent,	Sample No 17EL127 Dining Hall 1	< 1	PASS	4293
		The Glebe - Pencaitland - Tranent,	Sample No 17EL128 Dining Hall 2	< 1	PASS	4289
		The Glebe - Pencaitland - Tranent,	Sample No 17EL129 Kitchen Tap 1	< 1	PASS	1137
			Sample No 17EL130 Kitchen Tap 2	< 1	PASS	
North Berwick Nursery	1158	8a Law Road - North Berwick - East Lothian	Sample No 17EL131 Staffroom	< 1	PASS	042686
			Sample No 17EL132 TU Room 3	< 1	PASS	
North Berwick Sports Centre	1134	Grange Road - North Berwick - East Lothian	Not within FMS			501134
		Grange Road - North Berwick - East Lothian	Not within FMS			503273
		Grange Road - North Berwick - East Lothian	Not within FMS			7420
Musselburgh Burgh Primary School	1120	1A Kilwinning Street - Musselburgh - East Lothian	Sample No 17EL59 Dining Hall Cooler	< 1	PASS	001120
		1A Kilwinning Street - Musselburgh - East Lothian	Sample No 17EL60 Sick Bay	< 1	PASS	052885
		1A Kilwinning Street - Musselburgh - East Lothian	Sample No 17EL61 Middle Floor	< 1	PASS	052881
		1A Kilwinning Street - Musselburgh - East Lothian	Sample No 17EL62 Top Floor	< 1	PASS	1120
			Sample No 17EL63 Kitchen Tap Food Prep	< 1	PASS	
Elphinstone Primary School	1115	Main Street - Elphinstone - East Lothian	Sample No 17EL64 Water Cooler	< 1	PASS	03059
			Sample No 17EL65 Kitchen Food Prep Tap	< 1	PASS	
Aberlady Primary School	1108	Moor Road - Aberlady, Longniddry - East Lothian	Sample No 17EL66 Water Fountain	< 1	PASS	11008
			Sample No 17EL67 Kitchen Tap Food Prep	< 1	PASS	
Aubigny Sports Centre	1110	East Lothian Council - Mill Wynd - Haddington, East Lothian	Not within FMS			4500
		East Lothian Council - Mill Wynd - Haddington, East Lothian	Not within FMS			4503
St Gabriels Primary School	1142	South Grange Avenue - Prestonpans - East Lothian	Sample No 17EL68 Water Cooler	< 1	PASS	042141
			Sample No 17EL69 Kitchen Tap Food Prep	< 1	PASS	
Site	Contract	Address	Location of cooler (example staff room 1st floor)	Test Result	Pass/Fail	Cooler S/N

			Janitor to record on bottle location within school	Limit 10 ugPb/L		
Pinkie St Peters	1138	44 Pinkie Road - Musselburgh - East Lothian	Sample No 17EL71 kitchen Tap Food Prep	< 1	PASS	
Pinkie St Peters	1138	44 Pinkie Road - Musselburgh - East Lothian	Sample No 17EL72 Water Cooler Bottom Corridor	< 1	PASS	042674
		44 Pinkie Road - Musselburgh - East Lothian	Sample No 17EL73 Water Cooler Dining Hall	< 1	PASS	0321010
		44 Pinkie Road - Musselburgh - East Lothian	Sample No 17EL74 Water Cooler First Floor New Build	< 1	PASS	7822
Sample Taken 22/12/2016 result <1Pb/L		44 Pinkie Road - Musselburgh - East Lothian	School Sports Pavillion Kitchen	< 1	PASS	
Prestonpans Infant School	1139	West Loan - Prestonpans - East Lothian	Sample No 17EL75 Water Cooler 052874	< 1	PASS	052874
		West Loan - Prestonpans - East Lothian	Sample No 17EL76 Water Cooler 052877	< 1	PASS	052877
		West Loan - Prestonpans - East Lothian	Sample No 17EL77 Kitchen Tap Food Prep	< 1	PASS	
Loretto Primary School	1129	30 New Biggin - Musselburgh - East Lothian	Sample No 17EL78 Water Cooler Dining Room	< 1	PASS	04781
		30 New Biggin - Musselburgh - East Lothian	Sample No 17EL79 Kitchen Tap	< 1	PASS	
Longniddry Primary School	1128	Kitchener Crescent - Longniddry - East Lothian	Sample No 17EL80 Primary 6/7 Area	< 1	PASS	7839
		Kitchener Crescent - Longniddry - East Lothian	Sample No 17EL81 Primary 2/3 Area	< 1	PASS	6159
		Kitchener Crescent - Longniddry - East Lothian	Sample No 17EL82 Dining Room	< 1	PASS	7840
		Kitchener Crescent - Longniddry - East Lothian	Sample No 17EL83 Primary 1/2 Area	< 1	PASS	4508
		Kitchener Crescent - Longniddry - East Lothian	Sample No 17EL84 Kitchen Tap Food Prep	< 1	PASS	
MacMerry Primary School	1130	13 Main Road - MacMerry - East Lothian	Sample No 17EL85 P1/2 Area	< 1	PASS	052936
		13 Main Road - MacMerry - East Lothian	Sample No 17EL86 P6/7 Area	< 1	PASS	7624
		13 Main Road - MacMerry - East Lothian	Sample No 17EL87 Kitchen Tap Food Prep	< 1	PASS	
Law Primary School	1125	10 Law Road - North Berwick - East Lothian	Sample No 17EL133 Infant Area Water Cooler	< 1	PASS	4294
		10 Law Road - North Berwick - East Lothian	Sample No 17EL134 P3 Corridor	< 1	PASS	42760
		10 Law Road - North Berwick - East Lothian	Sample No 17EL135 Middle Area	< 1	PASS	42761
		10 Law Road - North Berwick - East Lothian	Sample No 17EL136 Primary 6	< 1	PASS	42881
		10 Law Road - North Berwick - East Lothian	Sample No 17EL137 Upper Area	< 1	PASS	52878
		10 Law Road - North Berwick - East Lothian	Sample No 17EL138 Temporary Unit	< 1	PASS	52879
		10 Law Road - North Berwick - East Lothian	Sample No 17EL139 Small Dining Room	< 1	PASS	52886
		10 Law Road - North Berwick - East Lothian	Sample No 17EL140 Large dining room	< 1	PASS	42173
			Sample No 17EL141 Kitchen Tap Cold Food Prep	< 1	PASS	
Dunbar Leisure Sports Centre	1157	East Lothian Council - Castlepark Barracks - Dunbar	Not within FMS			1157
		East Lothian Council - Castlepark Barracks - Dunbar	Not within FMS			7796
Dunbar Primary School	1114	Lammermuir Crescent - Dunbar - East Lothian	Sample No 17EL142 Dining Hall Water Cooler	< 1	PASS	52929

		Lammermuir Crescent - Dunbar - East Lothian	Sample No 17EL143 Water Cooler outside Room 6	< 1	PASS	52938
		Lammermuir Crescent - Dunbar - East Lothian	Sample No 17EL144 Water Cooler Staff Base P3	< 1	PASS	52941
		Lammermuir Crescent - Dunbar - East Lothian	Sample No 17EL145 Primary 2 Water Cooler	< 1	PASS	52942
		Lammermuir Crescent - Dunbar - East Lothian	Sample No 17EL146 Primary 1 Water Cooler	< 1	PASS	28206
		Lammermuir Crescent - Dunbar - East Lothian	Sample No 17EL147 Fruit Prep Kitchen Sink	< 1	PASS	52882
			Sample No 17EL148 Kitchen Tap cold Food Prep	< 1	PASS	
East Linton Primary School	1121	17 School Road - East Linton - East Lothian	Sample No 17EL149 Water Cooler Outside Music Room	< 1	PASS	42759
		17 School Road - East Linton - East Lothian	Sample No 17EL150 Water Cooler outside Kitchen	< 1	PASS	5940
			Sample No 17EL151 Kitchen Cold Tap Food Prep	< 1	PASS	
Penston House (East Lothian Council)	1107	(Paul lanetta) Penston House - MacMerry Industrial Estate - East Lothian	Not within FMS			6179
		(Paul lanetta) Penston House - MacMerry Industrial Estate - East Lothian	Not within FMS			7821
		(Paul lanetta) Penston House - MacMerry Industrial Estate - East Lothian	Not within FMS			V07896
		(Paul lanetta) Penston House - MacMerry Industrial Estate - East Lothian	Not within FMS			V09722
		(Paul lanetta) Penston House - MacMerry Industrial Estate - East Lothian	Not within FMS			U09953
		(Paul lanetta) Penston House - MacMerry Industrial Estate - East Lothian	Not within FMS			001879006
Site	Contract	Address	Location of cooler (example staff room 1st floor)	Test Result	Pass/Fail	Cooler S/N
			Janitor to record on bottle location within school	Limit 10 ugPb/L		
Brunton Hall & Theatre	8163	Provosts Room - Ladywell Way - Musselburgh				0002170403
Tynebank Resource Centre	8265	East Lothian Council - 16 Kirkview - Haddington	Not within FMS			23046
West Barns Primary	1149	17a School Brae - West Barns - East Lothian	Sample No 17EL156 Water Cooler	< 1	PASS	42678
			Sample No 17EL157 Kitchen cold Water Food Prep	< 1	PASS	
Whitecraig Primary School	1150	Whitecraig Crescent - Whitecraig - East Lothian	Sample No 17EL88 Infant Water Cooler	< 1	PASS	042753
		Whitecraig Crescent - Whitecraig - East Lothian	Sample No 17EL89 Upper Water Cooler	< 1	PASS	042748
		Whitecraig Crescent - Whitecraig - East Lothian	Sample No 17EL90 Kitchen Tap Food Prep	< 1	PASS	
Stoneyhill Primary School	1146	Clay Knowe Way - Musselburgh - East Lothian	Sample No 17EL91 Outside Bay 8 Cooler	< 1	PASS	042754

		Clay Knowe Way - Musselburgh - East Lothian	Sample No 17EL92 Cooler on First Floor	< 1	PASS	042747
		Clay Knowe Way - Musselburgh - East Lothian	Sample No 17EL93 Infant Cloakroom	< 1	PASS	042749
		Clay Knowe Way - Musselburgh - East Lothian	Sample No 17EL94 Mid School Cloakroom	< 1	PASS	042750
		Clay Knowe Way - Musselburgh - East Lothian	Sample No 17EL95 Kitchen Cold Tap	< 1	PASS	
		Clay Knowe Way - Musselburgh - East Lothian	Sample No 17EL96 Staff Room Mains Tap	< 1	PASS	
Prestonpans Primary School	1141	Preston Road - Prestonpans - East Lothian	Sample No 17EL97 Primary 4 Water Fountain	< 1	PASS	1141
		Preston Road - Prestonpans - East Lothian	Sample No 17EL98 Drinking Fountain Sports Hall	< 1	PASS	7825
		Preston Road - Prestonpans - East Lothian	Sample No 17EL99 Primary 6 Water Fountain	< 1	PASS	9313
		Preston Road - Prestonpans - East Lothian	Sample No 17EL100 Priamry 7 Water Fountain	< 1	PASS	2112
		Preston Road - Prestonpans - East Lothian	Sample No 17EL101 Kitchen Tap Cold Water Food Prep	< 1	PASS	
Ormiston Primary School	1136	Meadowbank - Ormiston - East Lothian	Sample No 17EL102 Priamry 7 Cloakroom	< 1	PASS	6176
		Meadowbank - Ormiston - East Lothian	Sample No 17EL103 Priamry 3/4 Cloakroom	< 1	PASS	04263
		Meadowbank - Ormiston - East Lothian	Sample No 17EL104 Kitchen Tap Food Prep	< 1	PASS	
Musselburgh Sports Centre	1133	101 Newbigging - Musselburgh - East Lothian				4505
		101 Newbigging - Musselburgh - East Lothian				74505
Humbie Primary School	1119	Main Road - Humbie - East Lothian	Sample No 17EL152 Water Cooler 84CWD31	< 1	PASS	22007
			Sample No 17EL153 Kitchen Tap Cold Water Food Prep	< 1	PASS	
Meadowmill Sports Centre	1131	16a Meadowmill - Tranent - East Lothian	Not within FMS			51981

Site	Contract	Address	Location of cooler (example staff room 1st floor)	Test Result	Pass/Fail	Cooler S/N
		16a Meadowmill - Tranent - East Lothian				7994
			Janitor to record on bottle location within school	Limit 10 ugPb/L		
Levenhall Nursery School	1126	Moir Place - Musselburgh - East Lothian	Not within FMS			7808
Haddington Joint School Campus	1118	Tynebank Road - Haddington - East Lothian	School already sampled upon completion 2013			496
School already sampled upon completion 2013	1118	Tynebank Road - Haddington - East Lothian				498
	1118	Tynebank Road - Haddington - East Lothian				495
	1118	Tynebank Road - Haddington - East Lothian				497
	1118	Tynebank Road - Haddington - East Lothian				493
	1118	Tynebank Road - Haddington - East Lothian				492
Sample Taken 19/02/2013 result <1 Pb/l		Tynebank Road - Haddington - East Lothian	School Kitchen Cold Water Tap (Food Prep) 2013	< 1	PASS	
John Muir House	1156	Brewery Park - Haddington - East Lothian	Not within FMS			11055579
		Brewery Park - Haddington - East Lothian	Not within FMS			1156
		Brewery Park - Haddington - East Lothian	Not within FMS			01062
Campie Primary School	1111	3 Stoneyhill Farm Road - Musselburgh - East Lothian	Sample No 17EL105 Unmarked Sample?	< 1	PASS	7793
		3 Stoneyhill Farm Road - Musselburgh - East Lothian	Sample No 17EL106 Unmarked Sample?	< 1	PASS	042756
		3 Stoneyhill Farm Road - Musselburgh - East Lothian	Sample No 17EL107 Unmarked Sample?	< 1	PASS	
East Saltoun Primary School	1122	Main Street - East Saltoun - East Lothian	Sample No 17EL154 Water Cooler	< 1	PASS	042682
			Sample No 17EL155 Kitchen Cold Water Tap Food Prep	< 1	PASS	
Kinweir Waste Services Depot/Transfer Station	6301	East Lothian Council - Waste Services - Tranent	Not within FMS			7365
		East Lothian Council - Waste Services - Tranent	Not within FMS			7366
		East Lothian Council - Waste Services - Tranent	Not within FMS			7367

ELC HIGH SCHOOLS controlled by FES Ltd						
Lead in Drinking Water Testing						
Site	Date of test	Address	Location of Cooler or Drinking water point	Test Result	Pass/ Fail	Corridor or Cooler Location
Musselburgh Grammar School	24/03/2017	86 Inveresk Road Musselburgh	Sample No 17EL166 Kitchen Food Prep	<1 UgPb/L	Pass	
		86 Inveresk Road Musselburgh	Sample No 17EL167 Dining Room	<1 UgPb/L	Pass	

		86 Inveresk Road Musselburgh	Sample No 17EL168 Social Space	<1 UgPb/L	Pass	
		86 Inveresk Road Musselburgh	Sample No 17EL169 Medical Room	<1 UgPb/L	Pass	
Knox Academy	24/03/2017	Pencaitland Road Haddington	Sample No 17EL170 Main kitchen	<1 UgPb/L	Pass	
		Pencaitland Road Haddington	Sample No 17EL171 Food Court	<1 UgPb/L	Pass	
		Pencaitland Road Haddington	Sample No 17EL172 Social Area	<1 UgPb/L	Pass	
		Pencaitland Road Haddington	Sample No 17EL173 PE Dept	<1 UgPb/L	Pass	
North Berwick High School	24/03/2017	Grange Road North Berwick	Sample No 17EL174 Kitchen Food Prep	<1 UgPb/L	Pass	
		Grange Road North Berwick	Sample No 17EL175 Social Space Cooler	<1 UgPb/L	Pass	
		Grange Road North Berwick	Sample No 17EL176 Dining Hall Cooler	<1 UgPb/L	Pass	S/N 030350
		Grange Road North Berwick	Sample No 17EL177 Dining Hall Cooler	<1 UgPb/L	Pass	S/N 030283
Dunbar Grammar School	24/03/2017	Summerfield Road Dunbar	Sample No 17EL178 Kitchen food prep	<1 UgPb/L	Pass	30270
		Summerfield Road Dunbar	Sample No 17EL179 Bistro	<1 UgPb/L	Pass	
		Summerfield Road Dunbar	Sample No 17EL180 Social Space	<1 UgPb/L	Pass	30280
		Summerfield Road Dunbar	Sample No 17EL181 PE Corridor	<1 UgPb/L	Pass	30273
Preston Lodge High School	24/03/2017	Park View Prestonpans	Sample No 17EL182 Kitchen Cold Tap	<1 UgPb/L	Pass	1011
		Park View Prestonpans	Sample No 17EL183 Social Space	<1 UgPb/L	Pass	1104
		Park View Prestonpans	Sample No 17EL184 PE Water Fountain	<1 UgPb/L	Pass	0050
		Park View Prestonpans	Sample No 17EL185 Dining Hall	<1 UgPb/L	Pass	1010
Ross High School	24/03/2017	Well Wynd Tranent	Sample No 17EL186 Kitchen Food Prep	<1 UgPb/L	Pass	0068

		Well Wynd Tranent	Sample No 17EL187 Social Space	<1 UgPb/L	Pass	OO21
		Well Wynd Tranent	Sample No 17EL188 PE Department	<1 UgPb/L	Pass	OO87
		Well Wynd Tranent	Sample NO 17EL189 Dining Hall	<1 UgPb/L	Pass	OO66
Olivebank Child & Family Centre	11/05/2017	104 Market Street, Musselburgh	Sample No 17EL207 Dolphin Room	<1 UgPb/L	Pass	
			Sample No 17EL208 Cub Room	<1 UgPb/L	Pass	
			Sample No 17EL209 Kitchen	<1 UgPb/L	Pass	
			Sample No 17EL210 Parents Room	<1 UgPb/L	Pass	
			Sample No 17EL211 Staff Toilet	<1 UgPb/L	Pass	
			Sample No 17EL212 Small Toilet	<1 UgPb/L	Pass	
			Sample No 17EL213 Penguin Room	<1 UgPb/L	Pass	
Lothian Villa Ravensheugh	11/05/2017	Tranent, EH33 1DT	Sample No 17EL205 Small Sink	<1 UgPb/L	Pass	
			Sample No 17EL206 Double Sink	<1 UgPb/L	Pass	
Lothian Villa Meadowmill	11/05/2017	Musselburgh EH21 7QB	Sample No 17EL203 Flat East of Building	<1 UgPb/L	Pass	
			Sample No 17EL204 Kitchen Sink	<1 UgPb/L	Pass	
Compass School Haddington	06/06/2017	11 West Road, Haddington EH41 3RD	Sample No 17EL237 Kitchen	<1 UgPb/L	Pass	
			Sample No 17EL238 Boys Water Fountain	<1 UgPb/L	Pass	
			Sample No 17EL239 Second Floor Water Fountain	<1 UgPb/L	Pass	
			Sample No 17EL240 Staff Room	2 UgPb/L	Pass	
			Sample No 17EL241 Girls Water Fountain	<1 UgPb/L	Pass	

Pear Tree Nursery, Haddington	16/06/2017	32 Meadowpark, Haddington EH41 4DS	Sample No 17EL248 Baby Sink	<1 UgPb/L	Pass	
			Sample No 17EL249 Downstairs Kitchen	<1 UgPb/L	Pass	
			Sample No 17EL250 Staff Kitchen	<1 UgPb/L	Pass	
Cherrytrees Nursery, Dunbar	16/06/2017	3 Abbey Road, Dunbar, EH42 1JP	Sample No 17EL252 Upstairs kitchen	<1 UgPb/L	Pass	
			Sample No 17EL253 Downstairs kitchen	<1 UgPb/L	Pass	
Wee Scones	16/06/2017	6 Haddington road, Tranent, EH33 1HW	Sample No 17EL251	<1 UgPb/L	Pass	
Camperdown	16/06/2017	159A High Street, Prestonpans, EH32 9AY	Sample No 17EL254	<1 UgPb/L	Pass	